

ABSTRAK

Nama : Hendra Dita Setiadi
Program Studi : Kesehatan Masyarakat
Judul : Gambaran Pemenuhan Sarana Proteksi Aktif dan Sarana Penyelamatan Jiwa berdasarkan *National Fire Protection Association* (NFPA) di Rumah Sakit X Kota Bekasi Tahun 2020.

Rumah sakit merupakan salah satu tempat yang memiliki risiko kebakaran. Berdasarkan data yang diperoleh Rumah Sakit X di Kota Bekasi, pada tahun 2020 telah terjadi kebakaran yang termasuk ke dalam kategori timbul asap sebanyak 3 kejadian dan timbulnya percikan api sebanyak 1 kejadian. Penelitian ini bertujuan untuk mengetahui gambaran pemenuhan sarana proteksi aktif dan sarana penyelamatan jiwa yang tersedia di Rumah Sakit X Kota Bekasi berdasarkan *National Fire Protection Association* (NFPA) 10, 13, 14, 72 dan 101. Jenis penelitian ini adalah penelitian deskriptif dengan pendekatan kualitatif melalui observasi lapangan, melakukan wawancara mendalam kepada informan, serta melakukan telaah dokumen. Hasil penelitian diketahui bahwa sebagian besar pemenuhan sarana proteksi kebakaran aktif, sarana penyelamatan jiwa, dan program pemeriksaan dan pemeliharaan sistem proteksi kebakaran berfungsi dan berjalan dengan baik, hal ini sesuai dengan *National Fire Protection Association* (NFPA) 10, 13, 14, 72 dan 101. Namun terdapat sebagian lain komponen utilitas yang kapasitasnya kurang dari yang ditetapkan dalam persyaratan. Untuk itu diperlukan pengadaan dan perbaikan bagi sarana proteksi aktif dan sarana penyelamatan jiwa yang belum memenuhi persyaratan, serta dilakukannya pemeliharaan terhadap sistem yang telah tersedia.

Kata Kunci: rumah sakit, sarana proteksi aktif, sarana penyelamatan jiwa
6 Bab, xi, 60, 9 gambar, 11 tabel, 3 lampiran
Pustaka: 29 (1995-2017)

ABSTRACT

Name : Hendra Dita Setiadi

Program Study : Public Health

Title : *Preview of Protection Level Facilities in Compliance and Life-saving Facilities based on the National Fire Protection Association (NFPA) at X Hospital Bekasi City in 2020.*

The hospital is one of the places where there is a risk of fire. Based on data obtained by Hospital X in Bekasi City, there were 3 fires which were included in the category of smoke and 1 sparks in 2020. This study aims to Preview of Protection Level Facilities in Compliance and Life-saving Facilities based on the National Fire Protection Association (NFPA) at X Hospital Bekasi City in 2020. This type of research is a descriptive study with a qualitative approach through field observation, conducting in-depth interviews with informant, and conducting documents. The results of the research are known that most of the fulfillment of active fire protection facilities, life saving facilities, and inspection and maintenance programs of fire protection systems are functioning and well-run, this is in accordance with the National Fire Protection Association (NFPA) 10, 13, 14, 72 and 101. However there are other components of the utility whose capacity is less than that specified in the requirements. Therefore, it is necessary to procurement and repair for the means of active protection and life saving facilities that have not fulfilled the requirements, and the maintenance of the system that has been available.

Keywords: The hospital, active fire protection facilities, life saving facilities, 6 Chapters, xi, 60, 9 pictures, 11 tables, 3 appendices

Library: 29 (1995-2017)